135

WTCI-616-P

Stanhope, New Jersey 07874
(201) 347-1200

USM
SINCE 1875

Cable: CAFCO, STANHOPE, N.J.
Telex: 136439 CAFCO STPE

UNITED STATES MINERAL PRODUCTS COMPANY

Mr. Phil Goz
Port Authority of N.Y. & N.J.
63 East One World Trade Center
New York, N.Y. 10048

March 15, 1983

Subject: CAFCO* BOND-SEAL*

Reference: New York World Trade Center

Dear Mr. Goz:

This is in response to inquiries made to our CAFCO Area Sales Representative, Mr. Allen Bessemer, concerning our CAFCO BOND-SEAL* used as an optional surface sealant over our CAFCO BLAZE-SHIELD* product for the above referenced project. The inquiries pertained to the product life expectancy of the BOND-SEAL as a surface sealant over CAFCO fire protection materials.

Please be advised that CAFCO BOND-SEAL used as a sealant over CAFCO fire protection materials should remain in-place and function in its intended capacity as a sealant as long as the material to which it is applied over remains in place, and dry.

If you should have any questions regarding this, please feel free to contact Mr. Bessemer at (201) 528-6858, or the undersigned.

Very truly yours,

John A. Kloepping

John A. Kloepping
CAFCO Architectural Sales Coordinator

cc: A. Bessemer
R. Felipe
F. Neuwirth
G. Schubert
D. Tafaro

JAK/gen

*Reg. U.S. Pat. Off.

PLAINTIFF'S EXHIBIT
PX-663

CAFCO® Spray-applied Thermal Insulations and Fireproofing Products
WEATHER-SHIELD® Systems FLEXHIDE® Roofing Membrane
CELLOFOAM® Brand Insulation/Construction System